



**WARREN-MORRISON  
VALVES LTD.**

## HYDROSTATIC TEST PROCEDURES

### HAND OPERATED SFV DIAPHRAGM VALVES – DN 65mm

TEST MEDIA – CLEAN MAINS WATER AT AMBIENT TEMPERATURE

#### SEAT TEST

Fully assembled valve will be secured on Test Rig and filled with Test Media. Ensure all air is vented from the valve prior to closure via the vent tap. Close valve and apply test pressure at 1.1 times the maximum valve rating. Check for leakage.

#### NOTE

Minimum test duration to be as specified in BS6755 part 1 table 4. The leakage rate is to BS6755 part 1 table 1 rate A, i.e. zero leakage..

#### BODY SHELL TEST

With valve still on test rig, open valve and completely fill with Test Media. Align the test plate on valve outlet and open vent tap, gently apply test pressure until test media escapes from the vent tap. Close vent tap and apply test pressure at 1.5 times the valve rating throughout the applied duration. Check body and body/bonnet joint for leakage.

#### NOTE

Minimum Test Durations are applied as specified in BS6755 part 1 table 4, unless otherwise applied.

Industrial pressure gauges to B.S.1780 shall have full scale reading of not less than 1.5 times the test pressure..

The test gauge shall be covered by a current test certificate, tested for calibration at a frequency that does not exceed 12 monthly intervals.

SIZE	RATING	TEST PRESSURES		TEST DURATION	
		SHELL	SEAT	SHELL	SEAT
65mm S 20	18 bar	27 bar	19 bar	1.00 MIN	1.00 MIN
65mm STD	15 bar	23 bar	16bar	1.00 MIN	1.00 MIN

Related documentation B.S.6755:Pt 1 - Pt2 UDC 621.646(620.1:532.11):614.84